



City of Austin

Public Works Department - Project Management Division

Bergstrom Tech Center 6800 Burleson Road, Building 312, Suite 200, Austin, Texas 78744

Date: March 25, 2021

PROJECT: West 9th and 12th Streets Water and Wastewater Renewal
CIP ID: 2231.339
IFB# 6100 CLMC842

SUBJECT: Answers to the Bidders Question #1 dated of the date of this letter, per 00100- IFV Article 1.(3)(C).

The following are the answers to the Bidders questions received on the above project. These answers do not modify the Contract. Any modification to the Contract will be through Addenda.

Q-1. Could you please clarify, from these bid items:

506S M1 for 4 Standard Pre-Cast Manhole with Castin-Place Base, 48 In Dia.
506S D for 2 Drop Manhole with Pre-Cast Base, 60 in Dia.
506S M4 for 15 Standard Pre-Cast Manhole w/Pre-cast Base, 4' Dia.
506S M5 for 1 Standard Pre-Cast Manhole w/Pre-cast Base, 5' Dia.

How many if any of these 22 manholes will require a corrosion protective lining?

A-1. All manholes will require lining per Specification 506, Section 506.4.R which requires a lining per SPL WW-511.

Laurie B. Thering, P.E.
Capital Delivery Project Manager
Public Works Department